

## TechLED Instructions

### I. Specifications

Voltage	220 - 240 V/AC
Frequency	50Hz
Emergency Mode Timer	3h (180min)
Operating Temperature	-20- +40
Operating Humidity	<93%RH
Power	3W (220 Lm)
IP	42
Connection	Mantida Não Mantida



### II. Instruction

- Switch off the power supply.
- Remove TechLED diffuser.
- TechLED allows you to choose between two modes. To select the desired option, follow the following steps:

Non-Maintained:



Maintained:



- If you wish to use a remote control, connect to the "Test +" e "Test -".
- Connect the battery's terminals to the plate's terminals.
- Attach the luminaire to the wall or ceiling.
- Put the diffuser in place to close the luminaire.
- Switch on the power supply.

### III. Accessories (not included, sold separately.)

- Box to embed in masonry:
  - Switch off the power supply.
  - Embed the box in the wall.
  - Place TechLED in the box.
  - Connect to TechLED as explained in point II of these instructions.
  - Switch on the power supply.



- Box to embed in plasterboard:
  - Switch off the power supply.
  - Attach the embedding clips to the ring.
  - Adjust the ring to TechLED.
  - Attach to the wall or ceiling.
  - Switch on the power supply.



- IP 65 Box:
  - Switch off the power supply.
  - Open the IP65 box (remove the diffuser).
  - Attach the cable glands supplied with TechLED.
  - Attach the box to the wall or ceiling.
  - Remove the TechLED diffuser.
  - Connect to TechLED as explained in point II of these instructions.
  - Close the IP65 box with its diffuser.
  - Switch on the power supply.



- Banner:
  - Switch off the power supply.
  - Remove the diffuser.
  - Apply the banner in the new diffuser and use the accessories to fix it.
  - Place the diffuser in the luminaire.
  - Switch on the power supply.

